



VILLAGE OF FRANKLIN PARK
OFFICE OF THE VILLAGE CLERK

9500 W. BELMONT AVENUE

FRANKLIN PARK, ILLINOIS 60131

TEL. 847-671-8242

Fax 847-671-7806

Email clerk@vofp.com

Village Clerk: *Tommy Thomson*

www.vofp.com

August 3, 2011

The following public notice and fact sheet has been posted as a public service for the Illinois Environmental Protection Agency. Please address all comments or concerns to the agency/personnel listed on the documents. The Village of Franklin Park is in no way involved with this item, except as a courtesy to post for public viewing.

Tommy Thomson
Village Clerk



ILLINOIS ENVIRONMENTAL PROTECTION AGENCY


1021 North Grand Avenue East, P.O. Box 19276, Springfield, Illinois 62794-9276 • (217) 782-2829
James R. Thompson Center, 100 West Randolph, Suite 11-300, Chicago, IL 60601 • (312) 814-6026

PAT QUINN, GOVERNOR

217/782-0610

July 29, 2011

Municipal Clerk
9506 Belmont Ave.
Franklin Park, Illinois 60131-2706



Re: Canadian Pacific Railway
Canadian Pacific Railway - Soo-Line Rail Road Company, Bensonville
NPDES Permit No. IL0002151
Public Notice of Permit

Municipal Clerk:

In accordance with the requirements of the Illinois Pollution Control Board regulations of 35 Ill. Adm. Code 309.109(a)(2)(A), the attached National Pollutant Discharge Elimination System Public Notice is sent to a municipality in the vicinity of the applicant. The Agency understands that the applicant may not be associated with the municipality to which it is sent.

Please post the attached National Pollutant Discharge Elimination System Public Notice for a period of 30 days. In addition, please complete and return the enclosed postcard indicating the date of posting. Should you choose not to post the attached notice, please indicate so on the postcard and return.

Thank you for your cooperation.

Sincerely,

Darin E. LeCrone, P.E.
Manager, Industrial Unit
Division of Water Pollution Control

DEL:LRL:11050301.daa

Attachments: Public Notice/Fact Sheet, Post Card

cc: Records Unit

NPDES Permit No. IL0002151
Notice No. LRL:11050301.daa

Public Notice Beginning Date: **July 29, 2011**

Public Notice Ending Date: **August 29, 2011**

National Pollutant Discharge Elimination System (NPDES)
Permit Program

Draft Reissued NPDES Permit to Discharge into Waters of the State

Public Notice/Fact Sheet Issued By:

Illinois Environmental Protection Agency
Bureau of Water,
Division of Water Pollution Control
Permit Section
1021 North Grand Avenue East
Post Office Box 19276
Springfield, Illinois 62794-9276
217/782-0610

Name and Address of Discharger:

Canadian Pacific Railway
501 Marquette Ave., Suite 1525
Minneapolis, MN 55402

Name and Address of Facility:

Canadian Pacific Railway - Soo-Line Rail Road Company,
Bensonville
11306 Franklin Ave.
Franklin Park, Illinois 60131
(Cook & DuPage County)

The Illinois Environmental Protection Agency (IEPA) has made a tentative determination to issue a NPDES permit to discharge into the waters of the state and has prepared a draft permit and associated fact sheet for the above named discharger. The Public Notice period will begin and end on the dates indicated in the heading of this Public Notice/Fact Sheet. The last day comments will be received will be on the Public Notice period ending date unless a commentor demonstrating the need for additional time requests an extension to this comment period and the request is granted by the IEPA. Interested persons are invited to submit written comments on the draft permit to the IEPA at the above address. Commentors shall provide his or her name and address and the nature of the issues proposed to be raised and the evidence proposed to be presented with regards to those issues. Commentors may include a request for public hearing. Persons submitting comments and/or requests for public hearing shall also send a copy of such comments or requests to the permit applicant. The NPDES permit and notice number(s) must appear on each comment page.

The application, engineer's review notes including load limit calculations, Public Notice/Fact Sheet, draft permit, comments received, and other documents are available for inspection and may be copied at the IEPA between 9:30 a.m. and 3:30 p.m. Monday through Friday when scheduled by the interested person.

If written comments or requests indicate a significant degree of public interest in the draft permit, the permitting authority may, at its discretion, hold a public hearing. Public notice will be given 45 days before any public hearing. Response to comments will be provided when the final permit is issued. For further information, please call Leslie Lowry at 217/782-0610.

The applicant is engaged in operation of a railroad, including light railcar maintenance, fueling of locomotives, and switching and terminal operations (SIC 4011 and 4013). Plant operation results in an intermittent discharge of stormwater runoff from the southeast yard from outfall 002, an intermittent discharge of stormwater runoff from outfall 003, an intermittent discharge of stormwater runoff from outfall 004, an intermittent discharge of stormwater runoff from the east yard from outfall 028, an intermittent discharge of stormwater runoff from outfall 029, and an intermittent discharge of stormwater runoff from the west yard from outfall 030.

The following modification is proposed:

Removing outfall 001 and adding two new stormwaters outfalls, 003 and 004.

Application is made for the existing discharges which are located in Cook & DuPage County, Illinois. The following information identifies the discharge point, receiving stream and stream classifications:

<u>Outfall</u>	<u>Receiving Stream</u>	<u>Latitude</u>	<u>Longitude</u>	<u>Stream Classification</u>	<u>Integrity Rating</u>
002	Silver Creek	41° 56' 25" North	87° 53' 30" West	General use	Not Rated
003	Silver Creek	41° 56' 26" North	87° 53' 31" West	General use	Not Rated
004	Silver Creek	41° 56' 24" North	87° 53' 26" West	General use	Not Rated
028	Silver Creek	41° 56' 30" North	87° 53' 45" West	General use	Not Rated
029	Silver Creek	41° 56' 35" North	87° 53' 35" West	General use	Not Rated
030	Unnamed Ditch Tributary to Addison Creek	41° 57' 00" North	87° 55' 36" West	General use	Not Rated

To assist you further in identifying the location of the discharge please see the attached map.

The stream segment GM-01 receiving the discharge from outfalls 002, 003, 004, 028, and 029 are not on the 2010 303(d) list of impaired waters and are not a biologically significant stream.

The stream segment GLA-04 receiving the discharge from outfall 030 is on the 2010 303(d) list of impaired waters and is a biologically significant stream.

The following parameters have been identified as the pollutants causing impairment:

<u>Potential Cause</u>	<u>Designated Use</u>
Alpha - BHC, alteration in streamside of littoral vegetative covers, aquatic algae, copper, hexachlorobenzene, other flow regime alterations; dissolved oxygen, phosphorus (total), polychlorinated biphenyls, sedimentation/siltation, and total suspended solids	Aquatic Life use

The discharges from the facility shall be monitored and limited at all times as follows:

PARAMETER	LOAD LIMITS lbs/day DAF (DMF)			REGULATION	CONCENTRATION LIMITS mg/L		
	30 DAY AVERAGE	DAILY MAXIMUM			30 DAY AVERAGE	DAILY MAXIMUM	REGULATION
<u>Outfall 002:</u> SWPPP							
<u>Outfall 003:</u> SWPPP							
<u>Outfall 004:</u> SWPPP							
<u>Outfall 028:</u> SWPPP							

PUBLIC NOTICED

PARAMETER	LOAD LIMITS lbs/day DAF (DMF)		REGULATION	CONCENTRATION LIMITS mg/L		
	30 DAY AVERAGE	DAILY MAXIMUM		30 DAY AVERAGE	DAILY MAXIMUM	REGULATION
<u>Outfall 029:</u>						
Flow (MGD)						
pH				6.5 - 9 S.C.s.u.		35 IAC 302.204
Total Suspended Solids				15	30	35 IAC 304.124
Oil/Grease				15	30	35 IAC 304.124
Phenols					0.1	35 IAC 302.208
PNAs (total)				Monitor Only		

Outfall 030:

SWPPP

The following explain the conditions of the proposed permit:

The Special Conditions clarify flow, pH, monitoring location, discharge monitoring report submission, stormwater, and define total PNAs.

